

SCAN HERE



PR-2023-0414-111198



Republic of the Philippines
VISAYAS STATE UNIVERSITY
 Visca, Baybay City, Leyte

PURCHASE REQUEST

PPMP No. : 161-5-1196-2023-2-0-3

PR No.: GF-2023-04-00651

Date: 04-14-2023

Dept./Office: ARIC

Category: **Construction**
and Electrical Supplies

Section/End-User: Sarah Jean C. Sugano

Project Title/Code: **Advanced Research and Innovation**
Center 2023

Funding Source: General Fund - MOOE

Item #	Item Description	Unit	Qty	Unit Cost	PAR/ICS	Total Cost
1	Fire alarm with Strobe light	unit	3	3,000.00		9,000.00

Specification:

Operating voltage Loop: 24V (18.5V?26V)

Standby current Loop: ?0.4mA

Indoor (Non-residential);Temperature: -10°C?+50°C

Relative Humidity: ?95%?40±2°C?

Sound level 75dB?115dB (A weighte

Basic flashing frequency 1Hz?1.5Hz

Certification: ISO9001/CE/ROHS/UL Listed

	TOTAL					9,000.00
--	--------------	--	--	--	--	-----------------

Purpose: Center use

Checked by:	Funds Available:
 PHLOEM D. GALUPO	 ALICIA M. FLORES
TWG - Construction and Electrical Supplies	HEAD, BUDGET OFFICE

Signature:	Requested by:	Noted by:	Approved by:
Printed Name:	SARAH JEAN C. SUGANO	MA. THERESA P. LORETO	EDGARDO E. TULIN
Designation:	END USER	UNIT HEAD, PROJECT LEADER	PRESIDENT, VSU