

SCAN HERE



PR-2023-0831-141878



Republic of the Philippines
VISAYAS STATE UNIVERSITY
 Visca, Baybay City, Leyte

PURCHASE REQUEST

PPMP No. : 176-1-1557-2023-7-0-88

PR No.: STF-2023-08-02068

Date: 08-31-2023

Dept./Office: ODPP

Category: **Construction
and Electrical Supplies**

Section/End-User: Rafael Rosario A. Juntilla

Funding Source: Special Trust Fund

Project Title/Code: Admin Electrical 2

Item #	Item Description	Unit	Qty	Unit Cost	PAR/ICS	Total Cost
1	NEMA 1, customized surface-mounted panel board, 100AT/100AF	assy	2	60,000.00		120,000.00

Specification:

NEMA 1, customized surface-mounted panel board, metal enclosure, G.I. #16, powder coated wrinkle gray color, corrosion resistant and pure copper bush bar with grounding terminal lugs and neutral bus.

Main:

1 - 100AT/100AF, 3 P, 240 volts, 18 kAIC, MCCB

Branches:

8 - 15AT, 10 kAIC, 240 Volts, 2 P 60 Hz MCB

12 - 20AT, 10 kAIC, 240 volts, 2 P 60 Hz MCB

4 - 30AT, 10 kAIC, 240 volts, 2 P 60 Hz MCB

2	NEMA 1, customized surface-mounted panel board, 200AT	assy	1	100,000.00		100,000.00
---	---	------	---	------------	--	------------

Specification:

NEMA 1, customized surface-mounted panel, metal enclosure, G.I. sheet # 16, powder coated wrinkle gray color, corrosion resistant and pure copper bush bar with grounding terminal lugs and neutral bus:

Main:

1 - 200AT/200AF, 3 p, 240 volts, 18 kAIC MCCB

Branches:

2 - 20AT, 10 kAIC, 240 volts, 2 P 60 Hz MCB

28 -30AT, 10 kAIC, 240 volts, 2 P 60 Hz MCB

6 -40AT, 10 kAIC, 240 volts, 2 P 60 Hz MCB

3	NEMA 1, customized surface-mounted panel board,200AT/200AF	assy	1	100,000.00		100,000.00
---	---	------	---	------------	--	------------

Specification:

NEMA 1, customized surface-mounted panel, metal enclosure, G.I. sheet # 16 powder coated wrinkle gray color, corrosion resistant and pure copper bush bar with grounding terminal lugs and neutral bus.

Main:

1 - 200AT/200AF, 3 p, 240 volts, 18 kAIC MCCB

Branches:

34 - 30AT, 10 kAIC, 240 volts, 2 P 60 Hz MCB

4	NEMA 1, customized surface-mounted panel board, 500 AT	assy	1	300,000.00		300,000.00
---	---	------	---	------------	--	------------

Specification:

NEMA 1, customized surface-mounted panel, metal enclosure, G.I. sheet #16, powder coated wrinkle gray color, corrosion resistant and pure copper bus bar with grounding terminal lugs, neutral bus with KWhr, Voltage and current monitor features.

Main:

1 - 500AT/500AF, 3P, 240 volts, 22 kAIC MCCB



Branches:

2 - 200AT/200AF, 18 kAIC 240 volts, 3 P 60 Hz MCCB

2 - 100AT/100AF, 18 kAIC, 240 volts, 3 P 60 Hz MCCB

	TOTAL					620,000.00
--	--------------	--	--	--	--	-------------------

Purpose: For Admin Electrical rehabilitation

Checked by:  PHLOEM D. GALUPO		Funds Available:  ALICIA M. FLORES <i>gpm OE</i>	
TWG - Construction and Electrical Supplies		HEAD, BUDGET OFFICE	
Signature: Printed Name: Designation:	Requested by:  RAFAEL ROSARIO A. JUNTILLA	Noted by:  MARLON G. BURLAS	Approved by:  EDGARDO E. TULIN
	END USER	UNIT HEAD, PROJECT LEADER	PRESIDENT, VSU