



Republic of the Philippines
VISAYAS STATE UNIVERSITY
Visca, Baybay City, Leyte

PURCHASE REQUEST

PPMP No. : **PPMP-2024-051724-0129**

PR No.: **STF-2024-05-01167**

Date: **05-22-2024**

Dept./Office: **DOPAC**

Category: **Laboratory
Equipment**

Section/End-User: **Jane M. Abapo**

Project Title/Code: **DoPAC-Fumehood Request**






Funding Source: **Special Trust Fund**

Item #	Item Description	Unit	Qty	Unit Cost	PAR/ICS	Total Cost
1	Laboratory Fumehood	unit	1	350,000.00		350,000.00

Specification:

Specifications

1. at least 4ft Nominal Width
2. Conforms to the following standards: ANSI Z9.5, ASHRAE 110, ASTM E84, CAN/CSA C22.2, NFPA 45, SEFA 1, UL
3. Enclosure height must be at least 59 inches
4. Must have LED lighting
5. With at least 2 service fixtures
6. Must come with remote fiberglass blower with 0.25 horsepower and is chemical resistant
7. Must come with manual duct damper and zero pressure weather cap
8. Must come with airflow monitor
9. Must come with corrosion-resistant epoxy resin 4 ft work surface compatible with the fume hood
10. Power Supply: AC 220 V \pm 10%, 50/ 60 Hz
11. Power Consumption: 400 W

TOTAL					350,000.00
Purpose: Laboratory Use					
Checked by:			Funds Available:		
 ELIZABETH S. QUEVEDO			 ALICIA M. FLORES		
TWG - Laboratory Equipment			HEAD, BUDGET OFFICE		
Signature:	Prepared by:	Noted by:	Approved by:		
Printed Name:	 JANE M. ABAPO	 ELIZABETH S. QUEVEDO	 PROSE IVY G. YEPES		
Designation:		UNIT HEAD, PROJECT LEADER	PRESIDENT, VSU		